

U.S. DEPARTMENT OF LABOR Occupational Safety and Health Administration	Form Approved OMB No. 34-R1387
MATERIAL SAFETY DATA SHEET	
Required under USDL Safety and Health Regulations for Ship Repairing, Shipbuilding, and Shipbreaking (29 CFR 1915, 1916, 1917)	

SECTION I	
MANUFACTURER'S NAME Krylon Dept., Div of Borden Chemical, Borden Inc ADDRESS (Number, Street, City, State, and ZIP Code) Ford & Washington Sts., Norristown, Pa. 19404	EMERGENCY TELEPHONE NO. (215) 278-2400 or 278-2456
CHEMICAL NAME AND SYNONYMS Krylon No. 1347 TEN ¹ Industrial Strength Spray (an aerosol unit to lubricate, penetrate, clean, protect, remove moisture)	TRADE NAME AND SYNONYMS
CHEMICAL FAMILY	

SECTION II - HAZARDOUS INGREDIENTS					
PAINTS, PRESERVATIVES, & SOLVENTS	%	TLV (Units)	ALLOYS AND METALLIC COATINGS	%	TLV (Units)
PIGMENTS			BASE METAL		
CATALYST			ALLOYS		
VEHICLE			METALLIC COATINGS		
SOLVENTS	Mineral Spirits	35 100 ppm	FILLER METAL PLUS COATING OR CORE FLUX		
ADDITIVES	Methyl Chloroform*	30 350 ppm	OTHERS		
OTHERS					
HAZARDOUS MIXTURES OF OTHER LIQUIDS, SOLIDS, OR GASES				%	TLV (Units)
*See sections VI and IX ref. Pyrolysis products.					

SECTION III - PHYSICAL DATA			
BOILING POINT (°F.)	n.a.	SPECIFIC GRAVITY (H ₂ O = 1)	less than water
VAPOR PRESSURE (mm Hg.)	n.a.	PERCENT VOLATILE BY VOLUME (%)	87%
VAPOR DENSITY (AIR = 1)	unknown	EVAPORATION RATE (Butylacetate = 1)	greater than one
SOLUBILITY IN WATER	slight	Container is under internal pressure of	
APPEARANCE AND ODOR	n.a.	about 60 pounds per square inch gauge at 70° F.	

SECTION IV - FIRE AND EXPLOSION HAZARD DATA			
FLASH POINT (Method used)	See attached page	FLAMMABLE LIMITS	See attached page
EXTINGUISHING MEDIA Release spray button if spray is burning, if discharged content is burning, treat as Class B fire. Dry chemical preferred.			
SPECIAL FIRE FIGHTING PROCEDURES Normal Class B fire procedures.			
UNUSUAL FIRE AND EXPLOSION HAZARDS If sprayed within 12 inches of open flame, spray may catch fire and burn like a blowtorch. (Not dangerous to unit; release spray button) If can is in a fire it will burst and release flammable content which should then be treated as a Class B fire.			

 PAGE (1)
 8/17/79

(Continued on reverse side)

 Form OSHA-20
 Rev. May 72