

U.S. DEPARTMENT OF LABOR
Occupational Safety and Health Administration

Form Approved
OMB No. 44-R1387

MATERIAL SAFETY DATA SHEET

Required under USDL Safety and Health Regulations for Ship Repairing,
Shipbuilding, and Shipbreaking (29 CFR 1915, 1916, 1917)

SECTION I

MANUFACTURER'S NAME Krylon Dept., Div of Borden Chemical, Borden Inc		EMERGENCY TELEPHONE NO. (215) 278-2400 or 278-2456
ADDRESS (Number, Street, City, State, and ZIP Code) Ford & Washington Sts., Norristown, Pa. 19404		
CHEMICAL NAME AND SYNONYMS	TRADE NAME AND SYNONYMS Krylon No. 1347 TEN*4 Industrial Strength Spray (an aerosol unit to lubricate, penetrate, clean, protect, remove moisture)	
CHEMICAL FAMILY		

SECTION II - HAZARDOUS INGREDIENTS

PAINTS, PRESERVATIVES, & SOLVENTS	%	TLV (Units)	ALLOYS AND METALLIC COATINGS	%	TLV (Units)
PIGMENTS			BASE METAL		
CATALYST			ALLOYS		
VEHICLE			METALLIC COATINGS		
SOLVENTS	Mineral Spirits	35 100 ppm	FILLER METAL PLUS COATING OR CORE FLUX		
ADDITIVES	Methyl Chloroform*	30 350 ppm	OTHERS		
OTHERS					
HAZARDOUS MIXTURES OF OTHER LIQUIDS, SOLIDS, OR GASES				%	TLV (Units)
*See sections VI and IX ref. Pyrolysis products.					

SECTION III - PHYSICAL DATA

BOILING POINT (°F.)	n.a.	SPECIFIC GRAVITY (H ₂ O=1)	Less than water
VAPOR PRESSURE (mm Hg.)	n.a.	PERCENT VOLATILE BY VOLUME (%)	87%
VAPOR DENSITY (AIR=1)	unknown	EVAPORATION RATE (Buacetate = 1)	greater than one
SOLUBILITY IN WATER	slight	Container is under internal pressure of	
APPEARANCE AND ODOR	n.a.	about 60 pounds per square inch gauge at 70° F.	

SECTION IV - FIRE AND EXPLOSION HAZARD DATA

FLASH POINT (Method used)	See attached page	FLAMMABLE LIMITS	See attached page	Lel	Uel
EXTINGUISHING MEDIA	Release spray button if spray is burning. If discharged content is burning, treat as Class B fire. Dry chemical preferred.				
SPECIAL FIRE FIGHTING PROCEDURES	Normal Class B fire procedures.				
UNUSUAL FIRE AND EXPLOSION HAZARDS	If sprayed within 17 inches of open flame, spray may catch fire and burn like a blowtorch. (Not dangerous to unit; release spray button) If can is in a fire it will burst and release flammable content which should then be treated as a Class B fire.				

PAGE (1)

(Continued on reverse side)

Form OSHA-20
Rev. May 72

8/17/79